

INSTRUCTIONS



Installation of Gas Port Fittings on Secador™ Desiccator Cabinets

Cat. Nos. F42071-0002, F42072-0002, F42073-0002 F42074-0002, F42074-1002

NOTE: The cabinet is not designed to withstand negative pressure within and there is a danger of implosion if a vacuum line is connected to it. Similarly, very high pressure gas entry is not advised, since this may rupture the cabinet.


The gas ports are for the purpose of introducing an atmosphere other than air. If Carbon Dioxide, Nitrogen or other gas is to be introduced, make sure that both stopcocks are open. If the gas is heavier than air, the source should be connected to the lower stopcock; if lighter than air, connect the source to the upper stopcock.

The gas should enter at a pressure of one to two psi to sweep out the air through the other stopcock. When it is felt that a sufficient exchange has been made, close the entry stopcock first, then close the exit stopcock. This will avoid pressure build-up in the cabinet.

Parts list:

Item 1	Stopcock (2)
Item 2	O-ring (2)
Item 3	Nut (2)

- Place the cabinet on a horizontal surface.
- Locate the two holes in the back of the cabinet.
- Referring to the illustration, slip one of the O-rings (Item 2) over the threaded end of the stopcock (Item 1).
- Insert the threaded end of the stopcock into one of the holes in the cabinet from the outside.
- Holding the stopcock in place with one hand screw the nut (Item 3) onto the threaded end by inserting your hand through the open door and hand tighten it.
- Using a 5/8" socket wrench, tighten the nut so the O-ring seats.
- Repeat the process with the second stopcock..



BEL-ART PRODUCTS

WAYNE, NJ 07470 USA

TEL: 1-800-4BEL-ART • FAX: 973 694-7199 • www.belart.com

942070070

Scienceware® is a reg. TM of Bel-Art Products

Bel-Art Products assumes no obligation or liability for any advice furnished by it, or for results obtained with respect to these products. All such advice is given and accepted at the buyer's risk.

02/04

INSTRUCTIONS



Installation of Gas Port Fittings on Secador™ Desiccator Cabinets

Cat. Nos. F42071-0002, F42074-0002, F42074-1002

NOTE: The cabinet is not designed to withstand negative pressure within and there is a danger of implosion if a vacuum line is connected to it. Similarly, very high pressure gas entry is not advised, since this may rupture the cabinet.


The gas ports are for the purpose of introducing an atmosphere other than air. If Carbon Dioxide, Nitrogen or other gas is to be introduced, make sure that both stopcocks are open. If the gas is heavier than air, the source should be connected to the lower stopcock; if lighter than air, connect the source to the upper stopcock.

The gas should enter at a pressure of one to two psi to sweep out the air through the other stopcock. When it is felt that a sufficient exchange has been made, close the entry stopcock first, then close the exit stopcock. This will avoid pressure build-up in the cabinet.

Parts list:

Item 1	Stopcock (2)
Item 2	O-ring (2)
Item 3	Nut (2)

- Place the cabinet on a horizontal surface.
- Locate the two holes in the back of the cabinet.
- Referring to the illustration, slip one of the O-rings (Item 2) over the threaded end of the stopcock (Item 1).
- Insert the threaded end of the stopcock into one of the holes in the cabinet from the outside.
- Holding the stopcock in place with one hand screw the nut (Item 3) onto the threaded end by inserting your hand through the open door and hand tighten it.
- Using a 5/8" socket wrench, tighten the nut so the O-ring seats.
- Repeat the process with the second stopcock..



BEL-ART PRODUCTS

WAYNE NJ 07470 USA

TEL: 1-800-4BEL-ART • FAX: 973 694-7199 • www.belart.com

942070070

Scienceware® is a reg. TM of Bel-Art Products

Bel-Art Products assumes no obligation or liability for any advice furnished by it, or for results obtained with respect to these products. All such advice is given and accepted at the buyer's risk.

02/04




Installation of Gas Port Fittings on Secador® Desiccator Cabinets

Cat. Nos. F42071-0009, F42072-1009, F42073-1009 and F42074-1009

NOTE: The cabinet is not designed to withstand negative pressure within and there is a danger of implosion if a vacuum line is connected to it. Similarly, very high pressure gas entry is not advised, since this may rupture the cabinet.

The gas ports are for the purpose of introducing an atmosphere other than air. If Carbon Dioxide, Nitrogen or other gas is to be introduced, make sure that both stopcocks are open. If the gas is heavier than air, the source should be connected to the lower stopcock; if lighter than air, connect the source to the upper stopcock.

The gas should enter at a pressure of one to two psi to sweep out the air through the other stopcock. When it is felt that a sufficient exchange has been made, close the entry stopcock first, then close the exit stopcock. This will avoid pressure build-up in the cabinet.



Parts list:

Item 1	Stopcock (2)
Item 2	O-ring (2)
Item 3	Nut (2)

- Place the cabinet on a horizontal surface.
- Locate the two holes in the back of the cabinet.
- Referring to the illustration, slip one of the O-rings (Item 2) over the threaded end of the stopcock (Item 1).
- Insert the threaded end of the stopcock into one of the holes in the cabinet from the outside.
- Holding the stopcock in place with one hand screw the nut (Item 3) onto the threaded end by inserting your hand through the open door and hand tighten it.
- Using a 5/8" socket wrench, tighten the nut so the O-ring seats.
- Repeat the process with the second stopcock.

BEL-ART PRODUCTS

661 Route 23 South, Wayne, NJ 07470-6814 USA
 TEL: 1-800-4BEL-ART • FAX: 973-694-7199 • www.belart.com

942070134

Scienceware® is a reg. TM of Bel-Art Products
 Bel-Art Products assumes no obligation or liability for any advice furnished by it, or for results obtained with respect to these products. All such advice is given and accepted at the buyer's risk.

06/09





Stacking Instructions for Vertically-Oriented Secador® Desiccator Cabinets

Cat. Nos. F42074-0430, F42074-0440, F42074-0442, F42074-0443, and F42074-0444

Up to three (3) vertically-oriented Secador® Desiccator Cabinets can be safely and securely stacked atop one another. Preserving limited lab space is critical, and these vertically stacking desiccators provide expanded desiccator space in a compact footprint.

The end caps on these desiccators have specially designed elements that snugly fit together to secure the stack. To vertically stack the desiccators, start by placing a desiccator on a smooth, level surface. Place the next desiccator on top of the first so that all four corners are in alignment with the bottom desiccator. While there is no audible click or locking sound, you'll know when the desiccators are properly secured because you will not be able to laterally move the top desiccator. Repeat these steps with the final top desiccator.

NOTE: Horizontally-oriented Secador® Desiccator Cabinets are not designed to stack atop each other.



BEL-ART PRODUCTS

661 Route 23 South, Wayne, NJ 07470-6814 USA
 TEL: 1-800-4BEL-ART • FAX: 973-694-7199 • www.belart.com